

# NORTH COUNTY FIRE PROTECTION DISTRICT

315 East Ivy Street · Fallbrook, California 92028-2138 · (760) 723-2010 · Fax (760) 723-2045 · www.ncfire.org

**BOARD OF DIRECTORS**  
LORI A. GRAHAM  
RUTH HARRIS  
KENNETH E. MUNSON  
RICHARD A. OLSON  
KATHLEEN THUNER

WILLIAM R. METCALF – Fire Chief/CEO  
ROBERT H. JAMES – Counsel  
LOREN A. STEPHEN-PORTER – Board Secretary

## DWELLING UNIT INSPECTIONS

Complex Name: \_\_\_\_\_

Address: \_\_\_\_\_ Date: \_\_\_\_\_

### Owners contact information:

Name: \_\_\_\_\_ Phone #: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

### Emergency Contact information:

Name: \_\_\_\_\_ Business Phone: \_\_\_\_\_

Address: \_\_\_\_\_ Home Phone: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

### Insure all the following have been done:

- Every unit has a smoke detector in the living space and in every bedroom/sleeping area.
- All smoke detectors are operable and tested every 6 months.
- Fire extinguishers have been serviced in the past year.
- No use of open flame cooking devices on combustible balconies or within 10ft. of combustible buildings (such as a barbeque).
- Fire sprinkler heads are unobstructed.
- Fire sprinkler control valves are open.
- Annual and 5 year inspection and maintenance, by C-16 contract, are done.

Remark: \_\_\_\_\_

As the owner or owner's agent, I certify that I have conducted the dwelling unit inspection.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**RETURN COMPLETED FORM TO:**  
North County Fire Protection District  
Fire Prevention Bureau  
315 E. Ivy St. Fallbrook, CA 92028-2138



PROUDLY SERVING THE COMMUNITIES OF FALLBROOK, BONSALE AND RAINBOW